

**Union County Splash Pad RFP**  
**Project Number UC-2015-001**  
**Questions and Answers**  
**September 18, 2015**

Questions submitted:

1. We understand the 9/9 meeting minutes stated that the new fence should be 5 feet tall, but after measuring onsite, it appears the existing outer fence is 6 ft. Please confirm 5 ft or 6 ft.
2. Drawing SW4- Detail 1 says 4,000 PSI concrete and Detail 4 says 3,500 PSI concrete. SW-8 says 3,500 PSI. Please confirm which to price.
3. Please confirm that there are no permit fees at all on this project.
4. Please confirm phase and voltage of power that will be provided to pump room.

Answers:

1. 6 ft. fence
2. 3,500 PSI
3. No permit fees
4. 3-phase